

Info @ DBE Services

From: McGregor, Jamie <Jamie.McGregor@uuplc.co.uk>
Sent: 01 September 2015 15:59
To: 'info@dbeservices.co.uk'
Cc: School Contact Line
Subject: Tank drainage confirmation

Good Afternoon Dave,

Please treat the following email as your written confirmation as requested earlier during our phonecall.

The latest advice that we can offer and confirm is that the flushing of the tanks does not require any sterilisation process. You would only need to completely drain the tank, refill, drain completely again, and then once refilled, allow the water to run for 10-15 minutes to flush out the system.

Hope this is what you needed.

Many Thanks

[Jamie McGregor](#)

Service Delivery Analyst / School Contact Line

Service Delivery

ICC – Customer Operations

United Utilities

08009127240

School.contactline@uuplc.co.uk

EMGateway3.uuplc.co.uk made the following annotations

The information contained in this e-mail is intended only for the individual to whom it is addressed. It may contain legally privileged or confidential information or otherwise be exempt from disclosure. If you have received this Message in error or there are any problems, please notify the sender immediately and delete the message from your computer. You must not use, disclose, copy or alter this message for any unauthorised purpose. Neither United Utilities Group PLC nor any of its subsidiaries will be liable for any direct, special, indirect or consequential damages as a result of any virus being passed on, or arising from the alteration of the contents of this message by a third party.

United Utilities Group PLC, Haweswater House, Lingley Mere
Business Park, Lingley Green Avenue, Great Sankey,
Warrington, WA5 3LP